

Report No.:

Test Time: 18.12.2019 13:22

Luminaire Property

Luminaire Manufacturer:

Luminaire Description: FG 180 4x40LED 0,35A 44W 3000K закаленное стекло IP65 N

Number of Lamps: 1

Luminous Length (mm): 1200

Luminous Width (mm): 180

Luminous Height (mm): 76

Voltage: 221.5 V

Current: 0.207 A

Power: 44.68 W

Power Factor: 0.973

Photometric Results

CIE Class: Direct

Total Rated Lamp Lumens: 5555.6 lm

Measurement Flux: 5555.6 lm

Efficiency: 100%

Downward Ratio: 100%

Upward Ratio: 0%

Field Angle(C0/C180,C90/C270,C45/C225,C135/315): 156.2, 148.6, 149.2, 149.1

Beam Angle(C0/C180,C90/C270,C45/C225,C135/315): 115.5, 115.1, 115.4, 115.4

Luminaire Efficacy Rating (LER): 124.39

Central Intensity: 1969.78 cd

Max. Intensity: 1970.61 cd

Pos of Max. Intensity: H22.5 V0


S/MH(C0/C180): 1.29

S/MH(C90/C270): 1.30

Picture Of Luminaire



Luminous Intensity Distribution Curve



— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 22.5

Gamma Plane (°):0.0-180.0:1.0

Test Lab:

Test Device: LSG-1800B

Test Type: TYPE C

Distance: 12.677 m



Temperature:

Humidity:

Operator:

Inspector:

Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:1.0


Test Device: LSG-1800B

Distance: 12.677 m

Humidity:

Inspector:



Luminous Intensity Distribution Curve(cd / klm)



Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	6385	5964	5449	4816	4041	3156	2097	1101	314
C90	8337	8079	7637	5872	3745	3056	2264	678	368
C180	6397	5970	5453	4835	4077	3191	2120	1129	310
C270	8768	8596	8344	7923	5731	3727	3043	2307	843

C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:1.0


Test Device: LSG-1800B

Distance: 12.677 m

Humidity:

Inspector:

Illuminance at a Distance



UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	18.7	20.0	19.0	20.3	20.5	19.3	20.6	19.6	20.8	21.1
3H	19.7	20.9	20.1	21.2	21.5	19.8	21.1	20.2	21.3	21.6
4H	20.0	21.1	20.3	21.4	21.7	20.0	21.1	20.3	21.4	21.7
6H	20.1	21.1	20.4	21.4	21.8	20.0	21.1	20.4	21.4	21.7
8H	20.1	21.1	20.4	21.4	21.7	20.0	21.0	20.4	21.4	21.7
12H	20.0	21.0	20.4	21.3	21.7	20.0	21.0	20.4	21.3	21.7
X=4H Y=2H	19.2	20.4	19.6	20.7	21.0	19.7	20.8	20.0	21.1	21.4
3H	20.4	21.4	20.8	21.7	22.0	20.3	21.3	20.7	21.7	22.0
4H	20.7	21.6	21.1	21.9	22.3	20.5	21.4	20.9	21.8	22.1
6H	20.8	21.6	21.3	22.0	22.4	20.6	21.4	21.1	21.8	22.2
8H	20.8	21.5	21.3	21.9	22.4	20.6	21.3	21.1	21.7	22.2
12H	20.8	21.4	21.3	21.9	22.3	20.6	21.2	21.1	21.7	22.1
X=8H Y=4H	20.7	21.4	21.2	21.8	22.3	20.6	21.3	21.0	21.7	22.1
6H	20.9	21.4	21.4	21.9	22.4	20.7	21.3	21.2	21.7	22.2
8H	20.9	21.4	21.4	21.8	22.3	20.7	21.2	21.2	21.7	22.2
12H	20.9	21.3	21.4	21.8	22.3	20.7	21.1	21.2	21.6	22.1
X=12H Y=4H	20.7	21.3	21.2	21.8	22.2	20.5	21.2	21.0	21.6	22.1
6H	20.9	21.4	21.3	21.8	22.3	20.7	21.2	21.2	21.6	22.1
8H	20.9	21.3	21.4	21.8	22.3	20.7	21.1	21.2	21.6	22.1
Variations with the observer position at spacings:										
S=1.0H	+0.2/-0.3					+0.1/-0.2				
S=1.5H	+0.4/-0.7					+0.5/-0.8				
S=2.0H	+0.9/-1.6					+1.5/-2.9				

Calculate in accordance with CIE Pub.117. The table is revised with 5556lm ($8\log(F/F_0) = 6.0$).

C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:1.0

Test Device: LSG-1800B

Distance: 12.677 m

Humidity:

Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 1.25									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.58	0.69	0.76	0.82	0.89	0.94	0.97	1.02	1.04	
	0.30		0.50	0.61	0.69	0.75	0.83	0.89	0.93	0.98	1.01	
	0.20		0.44	0.55	0.64	0.70	0.78	0.84	0.89	0.94	0.98	
0.50	0.50	0.20	0.56	0.66	0.74	0.79	0.86	0.90	0.93	0.98	1.00	
	0.30		0.49	0.60	0.67	0.73	0.81	0.86	0.90	0.94	0.97	
	0.20		0.44	0.55	0.63	0.68	0.77	0.82	0.86	0.92	0.95	
0.30	0.50	0.20	0.55	0.65	0.71	0.76	0.83	0.87	0.90	0.94	0.96	
	0.30		0.48	0.59	0.66	0.71	0.79	0.84	0.87	0.91	0.94	
	0.20		0.44	0.54	0.62	0.67	0.75	0.80	0.84	0.89	0.92	
0.00	0.00	0.00	0.41	0.52	0.59	0.64	0.72	0.77	0.80	0.85	0.87	
Rating:45W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 1.25									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.98	0.80	0.67	0.58	0.46	0.38	0.32	0.25	0.20	
	0.30		0.82	0.68	0.59	0.51	0.41	0.35	0.30	0.23	0.19	
	0.20		0.70	0.60	0.52	0.46	0.38	0.32	0.28	0.22	0.18	
0.50	0.50	0.20	0.94	0.77	0.64	0.56	0.44	0.39	0.30	0.23	0.19	
	0.30		0.80	0.66	0.57	0.50	0.40	0.33	0.28	0.22	0.18	
	0.20		0.69	0.59	0.51	0.45	0.37	0.31	0.27	0.21	0.17	
0.30	0.50	0.20	0.92	0.74	0.62	0.53	0.42	0.34	0.29	0.22	0.18	
	0.30		0.78	0.65	0.55	0.48	0.38	0.32	0.27	0.21	0.17	
	0.20		0.69	0.58	0.50	0.44	0.36	0.30	0.26	0.20	0.17	
0.00	0.00	0.00	0.58	0.48	0.41	0.35	0.28	0.23	0.20	0.15	0.12	
Rating:45W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 1.25									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.17	0.18	0.19	0.19	0.20	0.21	0.21	0.22	0.22	
	0.30		0.10	0.11	0.13	0.14	0.16	0.17	0.18	0.19	0.20	
	0.20		0.05	0.07	0.08	0.10	0.12	0.13	0.15	0.16	0.17	
0.50	0.50	0.20	0.16	0.17	0.18	0.19	0.19	0.20	0.20	0.21	0.21	
	0.30		0.10	0.11	0.13	0.14	0.15	0.16	0.17	0.18	0.19	
	0.20		0.05	0.07	0.08	0.10	0.11	0.13	0.14	0.16	0.17	
0.30	0.50	0.20	0.16	0.17	0.17	0.18	0.19	0.19	0.19	0.20	0.20	
	0.30		0.10	0.11	0.12	0.13	0.15	0.16	0.16	0.18	0.18	
	0.20		0.05	0.07	0.08	0.09	0.11	0.13	0.14	0.15	0.16	
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Rating:45W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												