

Lightsource Test Report

Product Infomation

Product Spec: FG 55 100W 5000K
Manufacturer: FAROS

Product Number: 7

CIE Colorimetric Parameters

Chromaticity coordinates: $x=0.3428$ $y=0.3550$ $u(u')=0.2085$ $v=0.3240$ $v'=0.4860$

CCT: $T_c=5100K$ ($duv=0.00265$)

Color Ratio: $R=0.154$ $G=0.798$ $B=0.049$

Peak Wavelength: 455.0nm

Half Bandwidth: 21.8nm

Dominant Wavelength: 568.6nm

Color Purity: 0.094

CRI: R_a : $R_a=84.2$


$R1=83$ $R2=87$ $R3=88$ $R4=86$ $R5=82$ $R6=80$ $R7=92$ $R8=75$

$R9=19$ $R10=67$ $R11=85$ $R12=49$ $R13=84$ $R14=93$ $R15=81$

Color Quality Scale: $Q_a=80.2$, $Q_f=80.6$, $Q_p=78.9$, $Q_g=90.0$

$Q1=82$ $Q2=97$ $Q3=78$ $Q4=69$ $Q5=73$ $Q6=76$ $Q7=84$ $Q8=91$

$Q9=96$ $Q10=88$ $Q11=82$ $Q12=81$ $Q13=81$ $Q14=73$ $Q15=77$



Photometric Parameters

Luminous Flux: 12087.54 lm Efficiency: 123.14 lm/W

Radiant Power: 37.425 W

Electric Parameters

Voltage: 220.90V

Current: 0.4510A

Power: 98.16W

Power Factor: 0.9850

Frequency: 49.99Hz

Test Infomation

Scan Range: 380~800:1nm

Stabilization Time: 0 ms

Max of Signal: 45045 (2790)

Photometric Method: sphere-spectroradiometer

Photometric Condition: Sphere diameter: 2.00m, 4PI

CCD Integration Time: 40.45 ms

Condition: $T_x=21.6^{\circ}C$, $T_i=22.5^{\circ}C$, R.H.:60%

Test Lab:

Operator:

Test Device: Lisun LMS-9000A(Plus)

Test Time: 2019-02-14 10:27:55

Inspector: