



Report No.: 1

Test Time: 14.11.2019 22:44

## Luminaire Property

Luminaire Manufacturer:

Luminaire Description: FG 595 (80) 24LED 0,35A 37W 4000K opal Hygiene Griliyto

Luminous Length (mm): 595

Luminous Width (mm): 595

Luminous Height (mm): 80

Voltage: 221.3 V

Current: 0.168 A

Power: 36.20 W

Power Factor: 0.973

## Photometric Results

CIE Class: Direct

Measurement Flux: 3872 lm

Downward Ratio: 99%

Total Rated Lamp Lumens: 3872.0 lm

Efficiency: 100%

Upward Ratio: 1%

Field Angle(C0/C180,C90/C270,C45/C225,C135/315): 164.7, 164.4, 164.5, 164.5

Beam Angle(C0/C180,C90/C270,C45/C225,C135/315): 111.1, 110.9, 111.0, 111.0

Luminaire Efficacy Rating (LER): 107.01

Central Intensity: 1348.44 cd

Max. Intensity: 1350.15 cd


Pos of Max. Intensity: H90 V3

S/MH(C0/C180): 1.24

S/MH(C90/C270): 1.24

Termogramma

Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:1.0



Test Device: LSG-1800B

Distance: 12.677 m

Humidity:

Inspector:


## Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 22.5  
 Test Lab:  
 Test Type: TYPE C  
 Temperature:  
 Operator:

Gamma Plane (°):0.0-180.0:1.0  
 Test Device: LSG-1800B  
 Distance: 12.677 m  
 Humidity:  
 Inspector:



## Luminous Intensity Distribution Curve(cd / klm)



## Lum Limit Curve

| Dazzle | Quality | Illuminance (lx) |      |      |       |       |       |       |       |
|--------|---------|------------------|------|------|-------|-------|-------|-------|-------|
| 1.15   | A       | 2000             | 1000 | 500  | <=300 |       |       |       |       |
| 1.50   | B       |                  | 2000 | 1000 | 500   | <=300 |       |       |       |
| 1.85   | C       |                  |      | 2000 | 1000  | 500   | <=300 |       |       |
| 2.20   | D       |                  |      |      | 2000  | 1000  | 500   | <=300 |       |
| 2.55   | E       |                  |      |      |       | 2000  | 1000  | 500   | <=300 |

a b c d e f g h



| L(cd/sq.m) | G45  | G50  | G55  | G60  | G65  | G70  | G75  | G80  | G85  |
|------------|------|------|------|------|------|------|------|------|------|
| C0         | 3103 | 2976 | 2840 | 2679 | 2503 | 2292 | 2029 | 1677 | 1140 |
| C90        | 3186 | 3068 | 2941 | 2795 | 2631 | 2439 | 2198 | 1876 | 1383 |
| C180       | 3095 | 2967 | 2824 | 2664 | 2473 | 2255 | 1984 | 1612 | 1056 |
| C270       | 2997 | 2861 | 2707 | 2537 | 2337 | 2098 | 1799 | 1390 | 733  |

C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:1.0


Test Device: LSG-1800B

Distance: 12.677 m

Humidity:

Inspector:

## Illuminance at a Distance



## UGR Table

|                                                    |                  |      |      |      |      |                |      |      |      |      |
|----------------------------------------------------|------------------|------|------|------|------|----------------|------|------|------|------|
| Reflectance:                                       |                  |      |      |      |      |                |      |      |      |      |
| Ceiling (cavity)                                   | 0.7              | 0.7  | 0.5  | 0.5  | 0.3  | 0.7            | 0.7  | 0.5  | 0.5  | 0.3  |
| Wall                                               | 0.5              | 0.3  | 0.5  | 0.3  | 0.3  | 0.5            | 0.3  | 0.5  | 0.3  | 0.3  |
| Reference plane                                    | 0.2              | 0.2  | 0.2  | 0.2  | 0.2  | 0.2            | 0.2  | 0.2  | 0.2  | 0.2  |
| Room dimensions                                    | Viewed crosswise |      |      |      |      | Viewed endwise |      |      |      |      |
| X=2H Y=2H                                          | 16.0             | 17.4 | 16.3 | 17.7 | 17.9 | 16.0           | 17.4 | 16.3 | 17.6 | 17.9 |
| 3H                                                 | 17.5             | 18.8 | 17.8 | 19.1 | 19.4 | 17.5           | 18.8 | 17.8 | 19.0 | 19.3 |
| 4H                                                 | 18.1             | 19.3 | 18.5 | 19.6 | 19.9 | 18.1           | 19.3 | 18.4 | 19.6 | 19.9 |
| 6H                                                 | 18.6             | 19.7 | 18.9 | 20.0 | 20.3 | 18.5           | 19.7 | 18.9 | 20.0 | 20.3 |
| 8H                                                 | 18.7             | 19.8 | 19.1 | 20.1 | 20.5 | 18.7           | 19.8 | 19.0 | 20.1 | 20.4 |
| 12H                                                | 18.8             | 19.8 | 19.2 | 20.2 | 20.5 | 18.7           | 19.8 | 19.1 | 20.1 | 20.5 |
| X=4H Y=2H                                          | 16.6             | 17.8 | 17.0 | 18.1 | 18.4 | 16.6           | 17.8 | 17.0 | 18.1 | 18.4 |
| 3H                                                 | 18.3             | 19.3 | 18.7 | 19.7 | 20.0 | 18.3           | 19.3 | 18.7 | 19.7 | 20.0 |
| 4H                                                 | 19.0             | 20.0 | 19.4 | 20.3 | 20.7 | 19.0           | 19.9 | 19.4 | 20.3 | 20.7 |
| 6H                                                 | 19.6             | 20.4 | 20.0 | 20.8 | 21.2 | 19.6           | 20.4 | 20.0 | 20.8 | 21.2 |
| 8H                                                 | 19.8             | 20.5 | 20.2 | 21.0 | 21.4 | 19.8           | 20.5 | 20.2 | 20.9 | 21.4 |
| 12H                                                | 19.9             | 20.6 | 20.4 | 21.0 | 21.5 | 19.9           | 20.6 | 20.3 | 21.0 | 21.4 |
| X=8H Y=4H                                          | 19.3             | 20.0 | 19.7 | 20.5 | 20.9 | 19.3           | 20.0 | 19.7 | 20.4 | 20.9 |
| 6H                                                 | 20.0             | 20.6 | 20.5 | 21.0 | 21.5 | 20.0           | 20.6 | 20.4 | 21.0 | 21.5 |
| 8H                                                 | 20.2             | 20.8 | 20.7 | 21.3 | 21.8 | 20.2           | 20.8 | 20.7 | 21.2 | 21.7 |
| 12H                                                | 20.4             | 20.9 | 20.9 | 21.4 | 21.9 | 20.4           | 20.9 | 20.9 | 21.4 | 21.9 |
| X=12H Y=4H                                         | 19.3             | 20.0 | 19.8 | 20.4 | 20.9 | 19.3           | 20.0 | 19.8 | 20.4 | 20.9 |
| 6H                                                 | 20.0             | 20.6 | 20.5 | 21.0 | 21.5 | 20.0           | 20.6 | 20.5 | 21.0 | 21.5 |
| 8H                                                 | 20.3             | 20.8 | 20.8 | 21.3 | 21.8 | 20.3           | 20.8 | 20.8 | 21.3 | 21.8 |
| Variations with the observer position at spacings: |                  |      |      |      |      |                |      |      |      |      |
| S=1.0H                                             | +0.2/-0.2        |      |      |      |      | +0.2/-0.2      |      |      |      |      |
| S=1.5H                                             | +0.3/-0.5        |      |      |      |      | +0.4/-0.5      |      |      |      |      |
| S=2.0H                                             | +0.6/-0.8        |      |      |      |      | +0.5/-1.0      |      |      |      |      |

Calculate in accordance with CIE Pub.117. The table is revised with 3872lm ( $8\log(F/F_0) = 4.7$ ).

## Utilisation Factor Table(Floor cavity)

| Utilisation Factors UF(F)                                                                                                                                                         |      |       | SHR NOM = 1.25 |      |      |      |      |      |      |      |      |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|----------------|------|------|------|------|------|------|------|------|--|
| Room Reflectance                                                                                                                                                                  |      |       | Room Index(RI) |      |      |      |      |      |      |      |      |  |
| Ceiling                                                                                                                                                                           | Wall | Floor | 0.75           | 1.00 | 1.25 | 1.50 | 2.00 | 2.50 | 3.00 | 4.00 | 5.00 |  |
| 0.70                                                                                                                                                                              | 0.50 | 0.20  | 0.56           | 0.66 | 0.74 | 0.79 | 0.86 | 0.91 | 0.95 | 1.00 | 1.03 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.48           | 0.58 | 0.66 | 0.72 | 0.80 | 0.86 | 0.90 | 0.95 | 0.99 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.42           | 0.53 | 0.60 | 0.66 | 0.75 | 0.81 | 0.85 | 0.92 | 0.96 |  |
| 0.50                                                                                                                                                                              | 0.50 | 0.20  | 0.54           | 0.64 | 0.71 | 0.76 | 0.83 | 0.88 | 0.91 | 0.96 | 0.98 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.47           | 0.57 | 0.64 | 0.70 | 0.78 | 0.83 | 0.87 | 0.92 | 0.95 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.42           | 0.52 | 0.59 | 0.65 | 0.73 | 0.79 | 0.83 | 0.89 | 0.92 |  |
| 0.30                                                                                                                                                                              | 0.50 | 0.20  | 0.53           | 0.62 | 0.69 | 0.73 | 0.80 | 0.84 | 0.88 | 0.92 | 0.94 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.46           | 0.56 | 0.63 | 0.68 | 0.75 | 0.80 | 0.84 | 0.89 | 0.92 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.42           | 0.51 | 0.58 | 0.64 | 0.72 | 0.77 | 0.81 | 0.86 | 0.90 |  |
| 0.00                                                                                                                                                                              | 0.00 | 0.00  | 0.39           | 0.49 | 0.56 | 0.61 | 0.68 | 0.73 | 0.77 | 0.82 | 0.85 |  |
| Rating:36W Photometrically tested without ceiling board.<br>Multiply UF values by service correction factors<br>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980 |      |       |                |      |      |      |      |      |      |      |      |  |

## Utilisation Factor Table(Wall)

| Utilisation Factors UF(W)                                                                                                                                                         |      |       | SHR NOM = 1.25 |      |      |      |      |      |      |      |      |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|----------------|------|------|------|------|------|------|------|------|--|
| Room Reflectance                                                                                                                                                                  |      |       | Room Index(RI) |      |      |      |      |      |      |      |      |  |
| Ceiling                                                                                                                                                                           | Wall | Floor | 0.75           | 1.00 | 1.25 | 1.50 | 2.00 | 2.50 | 3.00 | 4.00 | 5.00 |  |
| 0.70                                                                                                                                                                              | 0.50 | 0.20  | 1.01           | 0.84 | 0.71 | 0.62 | 0.50 | 0.42 | 0.36 | 0.28 | 0.23 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.84           | 0.71 | 0.62 | 0.55 | 0.45 | 0.38 | 0.33 | 0.26 | 0.22 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.72           | 0.62 | 0.55 | 0.50 | 0.41 | 0.35 | 0.31 | 0.25 | 0.21 |  |
| 0.50                                                                                                                                                                              | 0.50 | 0.20  | 0.97           | 0.80 | 0.68 | 0.60 | 0.48 | 0.43 | 0.34 | 0.26 | 0.22 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.82           | 0.70 | 0.60 | 0.54 | 0.44 | 0.37 | 0.32 | 0.25 | 0.21 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.71           | 0.61 | 0.54 | 0.48 | 0.40 | 0.34 | 0.30 | 0.24 | 0.20 |  |
| 0.30                                                                                                                                                                              | 0.50 | 0.20  | 0.94           | 0.77 | 0.66 | 0.57 | 0.46 | 0.38 | 0.32 | 0.25 | 0.21 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.81           | 0.68 | 0.59 | 0.52 | 0.42 | 0.36 | 0.31 | 0.24 | 0.20 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.71           | 0.61 | 0.53 | 0.48 | 0.39 | 0.33 | 0.29 | 0.23 | 0.19 |  |
| 0.00                                                                                                                                                                              | 0.00 | 0.00  | 0.60           | 0.51 | 0.44 | 0.39 | 0.32 | 0.27 | 0.23 | 0.18 | 0.15 |  |
| Rating:36W Photometrically tested without ceiling board.<br>Multiply UF values by service correction factors<br>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980 |      |       |                |      |      |      |      |      |      |      |      |  |

## Utilisation Factor Table(Ceiling cavity)

| Utilisation Factors UF(C)                                                                                                                                                         |      |       | SHR NOM = 1.25 |      |      |      |      |      |      |      |      |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|----------------|------|------|------|------|------|------|------|------|--|
| Room Reflectance                                                                                                                                                                  |      |       | Room Index(RI) |      |      |      |      |      |      |      |      |  |
| Ceiling                                                                                                                                                                           | Wall | Floor | 0.75           | 1.00 | 1.25 | 1.50 | 2.00 | 2.50 | 3.00 | 4.00 | 5.00 |  |
| 0.70                                                                                                                                                                              | 0.50 | 0.20  | 0.17           | 0.18 | 0.19 | 0.20 | 0.21 | 0.21 | 0.22 | 0.22 | 0.23 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.10           | 0.12 | 0.13 | 0.14 | 0.16 | 0.17 | 0.18 | 0.19 | 0.20 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.05           | 0.07 | 0.08 | 0.10 | 0.12 | 0.13 | 0.14 | 0.16 | 0.17 |  |
| 0.50                                                                                                                                                                              | 0.50 | 0.20  | 0.16           | 0.18 | 0.18 | 0.19 | 0.20 | 0.20 | 0.21 | 0.21 | 0.22 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.10           | 0.11 | 0.13 | 0.14 | 0.15 | 0.16 | 0.17 | 0.18 | 0.19 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.05           | 0.07 | 0.08 | 0.09 | 0.11 | 0.13 | 0.14 | 0.16 | 0.17 |  |
| 0.30                                                                                                                                                                              | 0.50 | 0.20  | 0.16           | 0.17 | 0.18 | 0.18 | 0.19 | 0.20 | 0.20 | 0.20 | 0.21 |  |
|                                                                                                                                                                                   | 0.30 |       | 0.10           | 0.11 | 0.12 | 0.13 | 0.15 | 0.16 | 0.17 | 0.18 | 0.18 |  |
|                                                                                                                                                                                   | 0.20 |       | 0.05           | 0.07 | 0.08 | 0.09 | 0.11 | 0.13 | 0.14 | 0.15 | 0.16 |  |
| 0.00                                                                                                                                                                              | 0.00 | 0.00  | 0.01           | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 |  |
| Rating:36W Photometrically tested without ceiling board.<br>Multiply UF values by service correction factors<br>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980 |      |       |                |      |      |      |      |      |      |      |      |  |